

RESOLUTION #15-16

**A RESOLUTION ADOPTING THE 2014 COMPLIANCE
MAINTENANCE ANNUAL REPORT FOR THE JACKSON
WASTEWATER TREATMENT FACILITY**

WHEREAS, the State of Wisconsin Department of Natural Resources requires a Compliance Maintenance Annual Report for the Village of Jackson Wastewater Treatment Plant; and

WHEREAS, the Village of Jackson Wastewater Treatment Plant Superintendent, the Village's Engineer, the Village Clerk and the Village Treasurer have completed the necessary information requested in the annual report; and

NOW, THEREFORE, BE IT RESOLVED, that the Village Board of the Village of Jackson, Washington County, Wisconsin, does hereby resolve that the Village Board has reviewed the Compliance Maintenance Annual Report, and has approved it for submission.

Introduced by: T. Mittelstadt

Seconded by: T. Olson

Vote: 7 Aye 0 Nay

Passed and Approved: October 13, 2015

Michael E. Schwab
Michael E. Schwab - Village President

Attest: Deanna L. Boldrey
Deanna L. Boldrey - Village Clerk-Treasurer

Proof of Posting:

I the undersigned, certify that I posted this Resolution on bulletin boards at the Village Hall, Post Office, and one other location in the Village.

Deanna L. Boldrey
Village Official

October 14, 2015
Date

Compliance Maintenance Annual Report

Jackson (Village) Wastewater Treatment Plant

Last Updated: Reporting For:
8/31/2015 2014

Influent Flow and Loading

1. Monthly Average Flows and (C)BOD Loadings

1.1 Verify the following monthly flows and (C)BOD loadings to your facility.

Outfall No. 701	Influent Monthly Average Flow, MGD	x	Influent Monthly Average (C)BOD Concentration mg/L	x	8.34	=	Influent Monthly Average (C)BOD Loading, lbs/day
January	0.6954	x	303	x	8.34	=	1,755
February	0.6593	x	301	x	8.34	=	1,655
March	0.9416	x	246	x	8.34	=	1,933
April	1.1717	x	222	x	8.34	=	2,173
May	0.9473	x	259	x	8.34	=	2,045
June	1.1992	x	237	x	8.34	=	2,366
July	0.8462	x	264	x	8.34	=	1,861
August	0.7433	x	289	x	8.34	=	1,789
September	0.6466	x	324	x	8.34	=	1,748
October	0.7075	x	305	x	8.34	=	1,799
November	0.6983	x	302	x	8.34	=	1,759
December	0.7881	x	258	x	8.34	=	1,698

2. Maximum Month Design Flow and Design (C)BOD Loading

2.1 Verify the design flow and loading for your facility.

Design	Design Factor	x	%	=	% of Design
Max Month Design Flow, MGD	1.875	x	90	=	1.6875
		x	100	=	1.875
Design (C)BOD, lbs/day	2980	x	90	=	2682
		x	100	=	2980

2.2 Verify the number of times the flow and (C)BOD exceeded 90% or 100% of design, points earned, and score:

	Months of Influent	Number of times flow was greater than 90% of	Number of times flow was greater than 100% of	Number of times (C)BOD was greater than 90% of design	Number of times (C)BOD was greater than 100% of design
January	1	0	0	0	0
February	1	0	0	0	0
March	1	0	0	0	0
April	1	0	0	0	0
May	1	0	0	0	0
June	1	0	0	0	0
July	1	0	0	0	0
August	1	0	0	0	0
September	1	0	0	0	0
October	1	0	0	0	0
November	1	0	0	0	0
December	1	0	0	0	0
Points per each		2	1	3	2
Exceedances		0	0	0	0
Points		0	0	0	0
Total Number of Points					0

0

Compliance Maintenance Annual Report

Jackson (Village) Wastewater Treatment Plant

Last Updated: Reporting For:
8/31/2015 2014

3. Flow Meter

3.1 Was the influent flow meter calibrated in the last year?

Yes

Enter last calibration date (MM/DD/YYYY)

No

If No, please explain:

4. Sewer Use Ordinance

4.1 Did your community have a sewer use ordinance that limited or prohibited the discharge of excessive conventional pollutants ((C)BOD, SS, or pH) or toxic substances to the sewer from industries, commercial users, hauled waste, or residences?

Yes

No

If No, please explain:

4.2 Was it necessary to enforce the ordinance?

Yes

No

If Yes, please explain:

5. Septage Receiving

5.1 Did you have requests to receive septage at your facility?

Septic Tanks

Holding Tanks

Grease Traps

Yes

Yes

Yes

No

No

No

5.2 Did you receive septage at your facility? If yes, indicate volume in gallons.

Septic Tanks

Yes

gallons

No

Holding Tanks

Yes

gallons

No

Grease Traps

Yes

gallons

No

5.2.1 If yes to any of the above, please explain if plant performance is affected when receiving any of these wastes.

Holding, Grease Decant, Septage, and Septage Decant is offloaded into two holding tanks then metered into the Influent stream eliminating slug loads. Grease is directly offloaded to the primary digester.

6. Pretreatment

6.1 Did your facility experience operational problems, permit violations, biosolids quality concerns, or hazardous situations in the sewer system or treatment plant that were attributable to commercial or industrial discharges in the last year?

Yes

No

If yes, describe the situation and your community's response.

Compliance Maintenance Annual Report

Jackson (Village) Wastewater Treatment Plant

Last Updated: Reporting For:
8/31/2015 2014

6.2 Did your facility accept hauled industrial wastes, landfill leachate, etc.?

Yes

No

If yes, describe the types of wastes received and any procedures or other restrictions that were in place to protect the facility from the discharge of hauled industrial wastes.

--

Total Points Generated	0
Score (100 - Total Points Generated)	100
Section Grade	A

Compliance Maintenance Annual Report

Jackson (Village) Wastewater Treatment Plant

Last Updated: Reporting For:
8/31/2015 2014

Effluent Quality and Plant Performance (BOD/CBOD)

1. Effluent (C)BOD Results

1.1 Verify the following monthly average effluent values, exceedances, and points for BOD or CBOD

Outfall No. 001	Monthly Average Limit (mg/L)	90% of Permit Limit > 10 (mg/L)	Effluent Monthly Average (mg/L)	Months of Discharge with a Limit	Permit Limit Exceedance	90% Permit Limit Exceedance
January	17	15.3	8	1	0	0
February	17	15.3	6	1	0	0
March	17	15.3	7	1	0	0
April	17	15.3	8	1	0	0
May	12	10.8	7	1	0	0
June	12	10.8	4	1	0	0
July	12	10.8	3	1	0	0
August	12	10.8	4	1	0	0
September	12	10.8	3	1	0	0
October	12	10.8	3	1	0	0
November	17	15.3	3	1	0	0
December	17	15.3	3	1	0	0

* Equals limit if limit is ≤ 10

Months of discharge/yr	12		
Points per each exceedance with 12 months of discharge		7	3
Exceedances		0	0
Points		0	0
Total number of points			0

NOTE: For systems that discharge intermittently to state waters, the points per monthly exceedance for this section shall be based upon a multiplication factor of 12 months divided by the number of months of discharge. Example: For a wastewater facility discharging only 6 months of the year, the multiplication factor is $12/6 = 2.0$

1.2 If any violations occurred, what action was taken to regain compliance?

2. Flow Meter Calibration

2.1 Was the effluent flow meter calibrated in the last year?

Yes

Enter last calibration date (MM/DD/YYYY)

05/30/2014

No

If No, please explain:

3. Treatment Problems

3.1 What problems, if any, were experienced over the last year that threatened treatment?

none

4. Other Monitoring and Limits

4.1 At any time in the past year was there an exceedance of a permit limit for any other pollutants such as chlorides, pH, residual chlorine, fecal coliform, or metals?

Yes

No

If Yes, please explain:

Compliance Maintenance Annual Report

Jackson (Village) Wastewater Treatment Plant

Last Updated: Reporting For:
8/31/2015 2014

4.2 At any time in the past year was there a failure of an effluent acute or chronic whole effluent toxicity (WET) test?

- Yes
- No

If Yes, please explain:

4.3 If the biomonitoring (WET) test did not pass, were steps taken to identify and/or reduce source(s) of toxicity?

- Yes
- No
- N/A

Please explain unless not applicable:

Total Points Generated	0
Score (100 - Total Points Generated)	100
Section Grade	A

Compliance Maintenance Annual Report

Jackson (Village) Wastewater Treatment Plant

Last Updated: Reporting For:
8/31/2015 2014

Effluent Quality and Plant Performance (Total Suspended Solids)

1. Effluent Total Suspended Solids Results

1.1 Verify the following monthly average effluent values, exceedances, and points for TSS:

Outfall No. 001	Monthly Average Limit (mg/L)	90% of Permit Limit >10 (mg/L)	Effluent Monthly Average (mg/L)	Months of Discharge with a Limit	Permit Limit Exceedance	90% Permit Limit Exceedance
January	12	10.8	5	1	0	0
February	12	10.8	3	1	0	0
March	12	10.8	3	1	0	0
April	12	10.8	3	1	0	0
May	12	10.8	4	1	0	0
June	12	10.8	3	1	0	0
July	12	10.8	2	1	0	0
August	12	10.8	2	1	0	0
September	12	10.8	2	1	0	0
October	12	10.8	2	1	0	0
November	12	10.8	1	1	0	0
December	12	10.8	1	1	0	0

* Equals limit if limit is <= 10

Months of Discharge/yr	12		
Points per each exceedance with 12 months of discharge:		7	3
Exceedances		0	0
Points		0	0
Total Number of Points			0

NOTE: For systems that discharge intermittently to state waters, the points per monthly exceedance for this section shall be based upon a multiplication factor of 12 months divided by the number of months of discharge.

Example: For a wastewater facility discharging only 6 months of the year, the multiplication factor is $12/6 = 2.0$

1.2 If any violations occurred, what action was taken to regain compliance?

Total Points Generated	0
Score (100 - Total Points Generated)	100
Section Grade	A

Compliance Maintenance Annual Report

Jackson (Village) Wastewater Treatment Plant

Last Updated: Reporting For:
8/31/2015 2014

Effluent Quality and Plant Performance (Ammonia - NH3)

1. Effluent Ammonia Results

1.1 Verify the following monthly and weekly average effluent values, exceedances and points for NH3

Outfall No. 001	Monthly Average NH3 Limit (mg/L)	Weekly Average NH3 Limit (mg/L)	Effluent Monthly Average NH3 (mg/L)	Monthly Permit Limit Exceedance	Effluent Weekly Average for Week 1	Effluent Weekly Average for Week 2	Effluent Weekly Average for Week 3	Effluent Weekly Average for Week 4	Weekly Permit Limit Exceedance
January	7		9.823529	1 0					
February	7		3.979375	0					
March	7		11.945	1					
April	4.3		3.943181	1 0					
May	5.7		1.794117	5 0					
June	3.9		1.155555	5 0					
July	3.9		3.133333	3 0					
August	3.9		4.017647	0 6					
September	3.9		1.970588	2 4					
October	4.3		3.061111	1 1					
November	7		1.035294	1 2					
December	7		1.166666	6 7					
Points per each exceedance of Monthly average:									10
Exceedances, Monthly:									1
Points:									10
Points per each exceedance of weekly average (when there is no monthly average):									2.5
Exceedances, Weekly:									0
Points:									0
Total Number of Points									10

10

NOTE: Limit exceedances are considered for monthly OR weekly averages but not both. When a monthly average limit exists it will be used to detect exceedances and generate points. This will be true even if a weekly limit also exists. When a weekly average limit exists and a monthly limit does not exist, the weekly limit will be used to detect exceedances and generate points.

1.2 If any violations occurred, what action was taken to regain compliance?

With the cold temps and low solids in basins we had trouble nitrifying. With operational changes proper nitrification process returned.

Total Points Generated	10
Score (100 - Total Points Generated)	90
Section Grade	B

Compliance Maintenance Annual Report

Jackson (Village) Wastewater Treatment Plant

Last Updated: Reporting For:
8/31/2015 2014

Effluent Quality and Plant Performance (Phosphorus)

1. Effluent Phosphorus Results

1.1 Verify the following monthly average effluent values, exceedances, and points for Phosphorus

Outfall No. 001	Monthly Average phosphorus Limit (mg/L)	Effluent Monthly Average phosphorus (mg/L)	Months of Discharge with a Limit	Permit Limit Exceedance
January	1	0.6	1	0
February	1	0.6	1	0
March	1	0.6	1	0
April	1	0.6	1	0
May	1	0.6	1	0
June	1	0.5	1	0
July	1	0.6	1	0
August	1	0.8	1	0
September	1	0.6	1	0
October	1	0.7	1	0
November	1	0.5	1	0
December	1	0.5	1	0
Months of Discharge/yr			12	
Points per each exceedance with 12 months of discharge:				10
Exceedances				0
Total Number of Points				0

0

NOTE: For systems that discharge intermittently to waters of the state, the points per monthly exceedance for this section shall be based upon a multiplication factor of 12 months divided by the number of months of discharge.

Example: For a wastewater facility discharging only 6 months of the year, the multiplication factor is $12/6 = 2.0$

1.2 If any violations occurred, what action was taken to regain compliance?

Total Points Generated	0
Score (100 - Total Points Generated)	100
Section Grade	A

Compliance Maintenance Annual Report

Jackson (Village) Wastewater Treatment Plant

Last Updated: Reporting For:
8/31/2015 2014

Biosolids Quality and Management

1. Biosolids Use/Disposal

1.1 How did you use or dispose of your biosolids? (Check all that apply)

- Land applied under your permit
- Publicly Distributed Exceptional Quality Biosolids
- Hauled to another permitted facility
- Landfilled
- Incinerated
- Other

NOTE: If you did not remove biosolids from your system, please describe your system type such as lagoons, reed beds, recirculating sand filters, etc.

1.1.1 If you checked Other, please describe:

2. Land Application Site

2.1 Last Year's Approved and Active Land Application Sites

2.1.1 How many acres did you have?

1315.30 acres

2.1.2 How many acres did you use?

123.3 acres

2.2 If you did not have enough acres for your land application needs, what action was taken?

2.3 Did you overapply nitrogen on any of your approved land application sites you used last year?

Yes (30 points)

No

2.4 Have all the sites you used last year for land application been soil tested in the previous 4 years?

Yes

No (10 points)

N/A

3. Biosolids Metals

Number of biosolids outfalls in your WPDES permit:

3.1 For each outfall tested, verify the biosolids metal quality values for your facility during the last calendar year.

Outfall No. 002 - ANAEROBIC LIQUID

Parameter	80% of Limit	H.Q. Limit	Ceiling Limit	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	80% Value	High Quality	Ceiling
Arsenic		41	75										4.63				0	0
Cadmium		39	85									<6.8					0	0
Copper		1500	4300		1070			1160				1290			970		0	0
Lead		300	840									<27.6					0	0
Mercury		17	57		<.0043			<.0045				<.0041			<1.7		0	0
Molybdenum	60		75									<27.6				0		0
Nickel	336		420									<27.6				0		0
Selenium	80		100									<27.6				0		0
Zinc		2800	7500									1430					0	0

3.1.1 Number of times any of the metals exceeded the high quality limits OR 80% of the limit for molybdenum, nickel, or selenium = 0

Exceedence Points

0 (0 Points)

Compliance Maintenance Annual Report

Jackson (Village) Wastewater Treatment Plant

Last Updated: Reporting For:
8/31/2015 2014

- 1-2 (10 Points)
 - > 2 (15 Points)
- 3.1.2 If you exceeded the high quality limits, did you cumulatively track the metals loading at each land application site? (check applicable box)
- Yes
 - No (10 points)
 - N/A - Did not exceed limits or no HQ limit applies (0 points)
 - N/A - Did not land apply biosolids until limit was met (0 points)
- 3.1.3 Number of times any of the metals exceeded the ceiling limits = 0
Exceedence Points
- 0 (0 Points)
 - 1 (10 Points)
 - > 1 (15 Points)
- 3.1.4 Were biosolids land applied which exceeded the ceiling limit?
- Yes (20 Points)
 - No (0 Points)
- 3.1.5 If any metal limit (high quality or ceiling) was exceeded at any time, what action was taken? Has the source of the metals been identified?

0

4. Pathogen Control (per outfall):

4.1 Verify the following information. If any information is incorrect, Contact Us.

Outfall Number:	002
Biosolids Class:	B
Bacteria Type and Limit:	F
Sample Dates:	01/01/2014 - 12/31/2014
Density:	61,346
Sample Concentration Amount:	CFU/G TS
Requirement Met:	Yes
Land Applied:	Yes
Process:	ANAER
Process Description:	Anaerobic Digestion *** As discussed with Jeff Deitsch, Fecals were not tested in 2014. The result entered is an average of previous years tests and is only included to allow the transmission of this form as it will not send if left blank. ***

0

4.2 If exceeded Class B limit or did not meet the process criteria at the time of land application.

4.2.1 Was the limit exceeded or the process criteria not met at the time of land application?

Yes (40 Points)

No

If yes, what action was taken?

5. Vector Attraction Reduction (per outfall):

5.1 Verify the following information. If any of the information is incorrect, Contact Us.

Compliance Maintenance Annual Report

Jackson (Village) Wastewater Treatment Plant

Last Updated: Reporting For:
8/31/2015 2014

Outfall Number:	002
Method Date:	12/31/2014
Option Used To Satisfy Requirement:	INJ
Requirement Met:	Yes
Land Applied:	Yes
Limit (if applicable):	
Results (if applicable):	

Outfall Number:	002
Method Date:	06/30/2014
Option Used To Satisfy Requirement:	INJ
Requirement Met:	Yes
Land Applied:	Yes
Limit (if applicable):	
Results (if applicable):	

Outfall Number:	002
Method Date:	09/30/2014
Option Used To Satisfy Requirement:	INJ
Requirement Met:	Yes
Land Applied:	No
Limit (if applicable):	
Results (if applicable):	

0

Outfall Number:	002
Method Date:	12/31/2014
Option Used To Satisfy Requirement:	INJ
Requirement Met:	Yes
Land Applied:	Yes
Limit (if applicable):	
Results (if applicable):	

5.2 Was the limit exceeded or the process criteria not met at the time of land application?

Yes (40 Points)

No

If yes, what action was taken?

6. Biosolids Storage

6.1 How many days of actual, current biosolids storage capacity did your wastewater treatment facility have either on-site or off-site?

- >= 180 days (0 Points)
- 150 - 179 days (10 Points)
- 120 - 149 days (20 Points)
- 90 - 119 days (30 Points)
- < 90 days (40 Points)
- N/A (0 Points)

6.2 If you checked N/A above, explain why.

Compliance Maintenance Annual Report

Jackson (Village) Wastewater Treatment Plant

Last Updated: Reporting For:
8/31/2015 2014

<input type="text"/>	0
7. Issues 7.1 Describe any outstanding biosolids issues with treatment, use or overall management: <input type="text"/>	

Total Points Generated	0
Score (100 - Total Points Generated)	100
Section Grade	A

Compliance Maintenance Annual Report

Jackson (Village) Wastewater Treatment Plant

Last Updated: Reporting For:
8/31/2015 2014

Staffing and Preventative Maintenance (All Treatment Plants)

1. Plant Staffing

1.1 Was your wastewater treatment plant adequately staffed last year?

Yes

No

If No, please explain:

We had two operators leave at the same time in April 2014. New hirers started in late July. All operation where maintain during that time.

Could use more help/staff for:

No

1.2 Did your wastewater staff have adequate time to properly operate and maintain the plant and fulfill all wastewater management tasks including recordkeeping?

Yes

No

If No, please explain:

2. Preventative Maintenance

2.1 Did your plant have a documented AND implemented plan for preventative maintenance on major equipment items?

Yes (Continue with question 2)

No (40 points)

If No, please explain, then go to question 3:

2.2 Did this preventative maintenance program depict frequency of intervals, types of lubrication, and other tasks necessary for each piece of equipment?

Yes

No (10 points)

2.3 Were these preventative maintenance tasks, as well as major equipment repairs, recorded and filed so future maintenance problems can be assessed properly?

Yes

Paper file system

Computer system

Both paper and computer system

No (10 points)

3. O&M Manual

3.1 Does your plant have a detailed O&M Manual that can be used as a reference when needed?

Yes

No

4. Overall Maintenance /Repairs

4.1 Rate the overall maintenance of your wastewater plant.

Excellent

Very good

Good

Fair

Poor

Describe your rating:

Compliance Maintenance Annual Report

Jackson (Village) Wastewater Treatment Plant

Last Updated: Reporting For:
8/31/2015 **2014**

In 2014 we improved the plants PM through better communication and updated the programing of tasks.

Total Points Generated	0
Score (100 - Total Points Generated)	100
Section Grade	A

Compliance Maintenance Annual Report

Jackson (Village) Wastewater Treatment Plant

Last Updated: Reporting For:
8/31/2015 2014

Operator Certification and Education

1. Operator-In-Charge

1.1 Did you have a designated operator-in-charge during the report year?

- Yes (0 points)
- No (20 points)

Name: MICHAEL A GAGNE / Jeff L. Deitsch

Certification No: 32808 / 12234

0

2. Certification Requirements

2.1 In accordance with Chapter NR 114.08 and 114.09, Wisconsin Administrative Code, what grade and subclass(es) were required for the operator-in-charge to operate the wastewater treatment plant and what grade and subclass(es) were held by the operator-in-charge?

Required:

4 - CEFHIJ; C - ACTIVATED SLUDGE; E - DISINFECTION; F - ANAEROBIC DIGESTION; H - FILTRATION; I - PHOSPHORUS REMOVAL; J - LABORATORY

Held:

4 - ABCEFGHIJ; 4 - A=PRIMARY SETTLING GRADE 4; B=TRICKLING FILTER/RBC GRADE 4; C=ACTIVATED SLUDGE GRADE 4; E=DISINFECTION GRADE 4; F=ANAEROBIC DIGESTION GRADE 4; G=MECHANICAL SLUDGE GRADE 4; H=FILTRATION GRADE 4; I=PHOSPHORUS REMOVAL GRADE 4; J=LABORATORY GRADE 4

0

2.2 Was the operator-in-charge certified at the appropriate level to operate this plant?

- Yes (0 points)
- No (20 points)

3. Succession Planning

3.1 In the event of the loss of your designated operator-in-charge, did you have a contingency plan to ensure the continued proper operation and maintenance of the plant that includes one or more of the following options (check all that apply)?

- One or more additional certified operators on staff
- An arrangement with another certified operator
- An arrangement with another community with a certified operator
- An operator on staff who has an operator-in-training certificate for your plant and is expected to be certified within one year
- A consultant to serve as your certified operator
- None of the above (20 points)

If "None of the above" is selected, please explain:

0

4. Continuing Education Credits

4.1 If you had a designated operator-in-charge, was the operator-in-charge earning Continuing Education Credits at the following rates?

Grades T, 1, and 2:

- Averaging 6 or more CECs per year.
- Averaging less than 6 CECs per year.

Grades 3 and 4:

- Averaging 8 or more CECs per year.
- Averaging less than 8 CECs per year.

Total Points Generated	0
Score (100 - Total Points Generated)	100
Section Grade	A

Compliance Maintenance Annual Report

Jackson (Village) Wastewater Treatment Plant

Last Updated: Reporting For:
8/31/2015 2014

Financial Management

1. Provider of Financial Information

Name: (XXX) XXX-XXXX
 Telephone:
 E-Mail Address (optional):

2. Treatment Works Operating Revenues

2.1 Are User Charges or other revenues sufficient to cover O&M expenses for your wastewater treatment plant AND/OR collection system ?

- Yes (0 points)
- No (40 points)

If No, please explain:

2.2 When was the User Charge System or other revenue source(s) last reviewed and/or revised?

Year:

- 0-2 years ago (0 points)
- 3 or more years ago (20 points)
- N/A (private facility)

2.3 Did you have a special account (e.g., CWF required segregated Replacement Fund, etc.) or financial resources available for repairing or replacing equipment for your wastewater treatment plant and/or collection system?

- Yes (0 points)
- No (40 points)

REPLACEMENT FUNDS [PUBLIC MUNICIPAL FACILITIES SHALL COMPLETE QUESTION 3]

3. Equipment Replacement Funds

3.1 When was the Equipment Replacement Fund last reviewed and/or revised?

Year:

- 1-2 years ago (0 points)
- 3 or more years ago (20 points)
- N/A

If N/A, please explain:

3.2 Equipment Replacement Fund Activity

3.2.1 Ending Balance Reported on Last Year's CMAR		\$	<input type="text" value="615,490.63"/>
3.2.2 Adjustments - if necessary (e.g. earned interest, audit correction, withdrawal of excess funds, increase making up previous shortfall, etc.)	+	\$	<input type="text" value="225,644.25"/>
3.2.3 Adjusted January 1st Beginning Balance		\$	<input type="text" value="841,134.88"/>
3.2.4 Additions to Fund (e.g. portion of User Fee, earned interest, etc.)	+	\$	<input type="text" value="49,689.31"/>
3.2.5 Subtractions from Fund (e.g., equipment replacement, major repairs - use description box 3.2.6.1 below*)	-	\$	<input type="text" value="63,689.63"/>
3.2.6 Ending Balance as of December 31st for CMAR Reporting Year		\$	<input type="text" value="827,134.56"/>

Compliance Maintenance Annual Report

Jackson (Village) Wastewater Treatment Plant

Last Updated: Reporting For:
8/31/2015 **2014**

All Sources: This ending balance should include all Equipment Replacement Funds whether held in a bank account(s), certificate(s) of deposit, etc.

3.2.6.1 Indicate adjustments, equipment purchases, and/or major repairs from 3.2.5 above.

Scada system upgrade with New Lab computers. Digester mixing upgrade

3.3 What amount should be in your Replacement Fund? \$

Please note: If you had a CWFP loan, this amount was originally based on the Financial Assistance Agreement (FAA) and should be regularly updated as needed. Further calculation instructions and an example can be found by clicking the HELP link under Info in the left-side menu.

3.3.1 Is the December 31 Ending Balance in your Replacement Fund above, (#3.2.6) equal to, or greater than the amount that should be in it (#3.3)?

- Yes
- No

If No, please explain.

0

4. Future Planning

4.1 During the next ten years, will you be involved in formal planning for upgrading, rehabilitating, or new construction of your treatment facility or collection system?

- Yes - If Yes, please provide major project information, if not already listed below.
- No

Project #	Project Description	Estimated Cost	Approximate Construction Year
1	The digestion process is proposed to have better mixing system installed, with possible a new cover for better plant efficiency	500000	2015

5. Financial Management General Comments

The Jackson Sewer utility continues to Follow the Master Plan of the plant along with the requirements from Wisconsin DNR during the discharge permit renewal process. Both have financial components that are essential in completing the outcome.

Total Points Generated	0
Score (100 - Total Points Generated)	100
Section Grade	A

Compliance Maintenance Annual Report

Jackson (Village) Wastewater Treatment Plant

Last Updated: Reporting For:
8/31/2015 2014

Sanitary Sewer Collection Systems

1. CMOM Program

1.1 Do you have a Capacity, Management, Operation & Maintenance (CMOM) requirement in your WPDES permit?

- Yes
- No

1.2 Did you have a documented (written records/files, computer files, video tapes, etc.) sanitary sewer collection system operation & maintenance (O&M) or CMOM program last calendar year?

- Yes (Continue with question 1)
- No (30 points) (Go to question 2)

1.3 Check the elements listed below that are included in your O&M or CMOM program.

Goals

Describe the specific goals you have for your collection system:

Cleaning and televising as much main line sewer as possible within budget and manpower.

Organization

Do you have the following written organizational elements (check only those that apply)?

- Ownership and governing body description
- Organizational chart
- Personnel and position descriptions
- Internal communication procedures
- Public information and education program

Legal Authority

Do you have the legal authority for the following (check only those that apply)?

- Sewer use ordinance Last Revised Date (MM/DD/YYYY) 01/10/2012
- Pretreatment/industrial control Programs
- Fat, oil and grease control
- Illicit discharges (commercial, industrial)
- Private property clear water (sump pumps, roof or foundation drains, etc.)
- Private lateral inspections/repairs
- Service and management agreements

Maintenance Activities (provide details in question 2)

Design and Performance Provisions

How do you ensure that your sewer system is designed and constructed properly?

- State plumbing code
- DNR NR 110 standards
- Local municipal code requirements
- Construction, inspection, and testing
- Others:

Overflow Emergency Response Plan:

Does your emergency response capability include (check only those that apply)?

- Alarm system and routine testing
- Emergency equipment
- Emergency procedures
- Communications/notifications (DNR, internal, public, media, etc.)

Capacity Assurance:

How well do you know your sewer system? Do you have the following?

- Current and up-to-date sewer map
- Sewer system plans and specifications

Compliance Maintenance Annual Report

Jackson (Village) Wastewater Treatment Plant

Last Updated: Reporting For:
8/31/2015 2014

- Manhole location map
 - Lift station pump and wet well capacity information
 - Lift station O&M manuals
- Within your sewer system have you identified the following?
- Areas with flat sewers
 - Areas with surcharging
 - Areas with bottlenecks or constrictions
 - Areas with chronic basement backups or SSOs
 - Areas with excess debris, solids, or grease accumulation
 - Areas with heavy root growth
 - Areas with excessive infiltration/inflow (I/I)
 - Sewers with severe defects that affect flow capacity
 - Adequacy of capacity for new connections
 - Lift station capacity and/or pumping problems
- Annual Self-Auditing of your O&M/CMOM Program to ensure above components are being implemented, evaluated, and re-prioritized as needed
- Special Studies Last Year (check only those that apply):
- Infiltration/Inflow (I/I) Analysis
 - Sewer System Evaluation Survey (SSES)
 - Sewer Evaluation and Capacity Management Plan (SECAP)
 - Lift Station Evaluation Report
 - Others:

2. Operation and Maintenance

2.1 Did your sanitary sewer collection system maintenance program include the following maintenance activities? Complete all that apply and indicate the amount maintained.

Cleaning	<input type="text" value="8"/>	% of system/year
Root removal	<input type="text" value=".01"/>	% of system/year
Flow monitoring	<input type="text" value="0"/>	% of system/year
Smoke testing	<input type="text" value="0"/>	% of system/year
Sewer line televising	<input type="text" value="4.2"/>	% of system/year
Manhole inspections	<input type="text" value=".6"/>	% of system/year
Lift station O&M	<input type="text" value="1"/>	# per L.S./year
Manhole rehabilitation	<input type="text" value="0"/>	% of manholes rehabbed
Mainline rehabilitation	<input type="text" value="0"/>	% of sewer lines rehabbed
Private sewer inspections	<input type="text" value="0"/>	% of system/year
Private sewer I/I removal	<input type="text" value=".01"/>	% of private services

Please include additional comments about your sanitary sewer collection system below:

Through property maintenance program, we continue to find bad laterals and have them repaired. The Jackson WWTF will continue to repair, replace, and maintain the collection system as much as possible within budget and manpower.

Compliance Maintenance Annual Report

Jackson (Village) Wastewater Treatment Plant

Last Updated: Reporting For:
8/31/2015 2014

3. Performance Indicators

3.1 Provide the following collection system and flow information for the past year.

23.26	Total actual amount of precipitation last year in inches
34.8	Annual average precipitation (for your location)
40.69	Miles of sanitary sewer
1	Number of lift stations
0	Number of lift station failures
0	Number of sewer pipe failures
0	Number of basement backup occurrences
0	Number of complaints
.837	Average daily flow in MGD (if available)
1.2	Peak monthly flow in MGD (if available)
4.72	Peak hourly flow in MGD (if available)

3.2 Performance ratios for the past year:

0.00	Lift station failures (failures/year)
0.00	Sewer pipe failures (pipe failures/sewer mile/yr)
0.00	Sanitary sewer overflows (number/sewer mile/yr)
0.00	Basement backups (number/sewer mile)
0.00	Complaints (number/sewer mile)
1.4	Peaking factor ratio (Peak Monthly:Annual Daily Avg)
5.6	Peaking factor ratio (Peak Hourly:Annual Daily Avg)

4. Overflows

LIST OF SANITARY SEWER (SSO) AND TREATMENT FACILITY (TFO) OFERFLOWS REPORTED **

Date	Location	Cause	Estimated Volume (MG)
None reported			

** If there were any SSOs or TFOs that are not listed above, please contact the DNR and stop work on this section until corrected.

5. Infiltration / Inflow (I/I)

5.1 Was infiltration/inflow (I/I) significant in your community last year?

Yes

No

If Yes, please describe:

5.2 Has infiltration/inflow and resultant high flows affected performance or created problems in your collection system, lift stations, or treatment plant at any time in the past year?

Yes

No

If Yes, please describe:

5.3 Explain any infiltration/inflow (I/I) changes this year from previous years:

We continue to repair private lateral when found to be compromised.

Compliance Maintenance Annual Report

Jackson (Village) Wastewater Treatment Plant

Last Updated: Reporting For:
8/31/2015 2014

5.4 What is being done to address infiltration/inflow in your collection system?

The Village will continue to address the I&I by replacing old main line and manhole repair as feasible. Will continue to Tv Private laterals.

Total Points Generated	0
Score (100 - Total Points Generated)	100
Section Grade	A

Compliance Maintenance Annual Report

Jackson (Village) Wastewater Treatment Plant

Last Updated: Reporting For:
8/31/2015 2014

Grading Summary

WPDES No: 0021806

SECTIONS	LETTER GRADE	GRADE POINTS	WEIGHTING FACTORS	SECTION POINTS
Influent	A	4	3	12
BOD/CBOD	A	4	10	40
TSS	A	4	5	20
Ammonia	B	3	5	15
Phosphorus	A	4	3	12
Biosolids	A	4	5	20
Staffing/PM	A	4	1	4
OpCert	A	4	1	4
Financial	A	4	1	4
Collection	A	4	3	12
TOTALS			37	143
GRADE POINT AVERAGE (GPA) = 3.86				

Notes:

- A = Voluntary Range (Response Optional)
- B = Voluntary Range (Response Optional)
- C = Recommendation Range (Response Required)
- D = Action Range (Response Required)
- F = Action Range (Response Required)

Compliance Maintenance Annual Report

Jackson (Village) Wastewater Treatment Plant

Last Updated: Reporting For:
8/31/2015 2014

Resolution or Owner's Statement

Name of Governing
Body or Owner:

Village of Jackson

Date of Resolution or
Action Taken:

10/13/2015

Resolution Number:

15-16

ACTIONS SET FORTH BY THE GOVERNING BODY OR OWNER RELATING TO SPECIFIC CMAR SECTIONS (Optional for grade A or B. Required for grade C, D, or F. Regardless of grade, required for Collection Systems if SSOs were reported):

Influent Flow and Loadings: Grade = A

Effluent Quality: BOD: Grade = A

Effluent Quality: TSS: Grade = A

Effluent Quality: Ammonia: Grade = B

Effluent Quality: Phosphorus: Grade = A

Biosolids Quality and Management: Grade = A

Staffing: Grade = A

Operator Certification: Grade = A

Financial Management: Grade = A

Collection Systems: Grade = A

ACTIONS SET FORTH BY THE GOVERNING BODY OR OWNER RELATING TO THE OVERALL GRADE POINT AVERAGE AND ANY GENERAL COMMENTS

(Optional for G.P.A. greater than or equal to 3.00, required for G.P.A. less than 3.00)

G.P.A. = 3.86